

POWERITE ACTUATED VALVES

ATEX DIRECTIVE 2014/34/EU



In compliance with ATEX directive 2014/34/EU, actuated valves are supplied as a single unit with a single declaration of conformity for each assembly.

In accordance with the latest standards BS EN ISO 80079-36 and BS EN ISO 80079-37, each assembly undergoes a full conformity assessment and is supplied with the following:

- Actuated valve declaration of conformity
- Ancillary equipment declaration of conformities
- Actuated valve instructions for safe use
- Individual equipment IOMs
- GA Drawing with parts list (upon request)
- Functional test certificate (upon request of customer)

Each assembly is labelled stating:

- The actuated valve part number
- Unique serial number
- Full ATEX rating of the actuated valve
- Maximum allowable ambient temperature
- Maximum allowable media temperature
- Maximum allowable travel time

TYPE: XXXXXXXXXXXXXXXX
Serial No: xxxxxxxx



KINETROL 16 ATEX 0154
h II 2G c IIX TX Gb
h II 2D c IIIX XX°C Db
Tamb -XX°C to XX°C

Process MediaTemp -XX°C to XX°C
Min. 90° Travel Time = XXX sec

KINETROL

GU9 9NU, UK BUILT XXXX



0518

99-033-36

Go to Powerite website for full details



powerite
division of Kinetrol Ltd

Tel: 01902 780700

Fax: 01902 780701

Email: enquiries@powerite.co.uk

www.powerite.co.uk